

BONHAM, TX UTILITY CAPACITY OVERVIEW



Utility	Provider	Capacity	Comments
Electric	Oncor – indicates electric service capacity is not an issue.	Need load data to model specifics	Extension Required: approx. 3,200 ft.
Natural Gas	Atmos Energy – 4” line, 750 psi	Line is set to 350 #s with the current load. Growth capacity of about 400-600 MCFH with an outlet pressure of 250 #s.	Onsite
Water	City - 8” line	Flow tested at 850 gpm (2/26/15)	Onsite
Sewer	City - 15” line (Plant has additional 750,000 GPD unused capacity)	750,000 GPD available	Onsite
Telco/Data	CableOne (multiple provider potential)	Up to 1 GHz, or 100MHz Coax if lesser capacity	Fiber-optic cable in TX Hwy 56 R-O-W.